IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR William H. Coulter DATE April 11, '78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N T.R on S.R. 2133 T.R on S.R. 2137 .6 or 1/4 mi. T.L. at Toba Gallihers residence at end of driv S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Cecil loam
Percolation Rate —
Topography C-10%
Depth to Water Table unk
Rock or other impervious formations none abv

Lot Area acreage



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10" +
Water Supply: Individual (✓)
Public ( )

Installed by Eddie Yountz

IMPROVEMENTS PERMIT BY David R. Henson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Henson DATE April 11, '78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold