IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

13938

OWNER OR CONTRACTOR LEON BARKER DATE 2/4/92 PERMIT NO. 12H-A-47

PHONE: Business _____ Home _____

LOCATION US 21 N, ON (R) PAST MT. BETHEL CHURCH ROAD

SUBDIVISION NAME EXISTING SYSTEM LOT NO. 3' ± 150' SECTION OR BLOCK NO. _____ S.R. No. _____

D. Box

House ( ) Mobile Home ( ) Business (✓) Other _____

No. Bedrooms — No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area AMPLE

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

Character & Porosity of Soil PS

Percolation Rate .4GPD/FT² (MEAN=.25)

Topography 2-4% LS

Depth to Water Table >4'

Rock or other impervious formations NONE

SEPTIC TANK (1500)

1200 PUMP TANK CRS 2/22/91

1500 SEPTIC TANK 11/4/91

Size of Tank _____ Gals.

Nitrification Field:


No. of Lines 5 - EXISTING

Sq. Ft 2250 Linear Ft. 750

Depth of Stone in Lines 12"

Water Supply: Individual ( )

Public (✓)



Plot of System

Installed by SAMMY REAVES

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HEDRICK

COMMENTS: ① FORMER RESTAURANT LOCATED IN TACK SHOP BUILDING IS NOW DISCONNECTED FROM SYSTEM & WILL REMAIN DEACTIVATED.
② SYSTEM SIZED TO ACCOMMODATE CONV. STORE W/ 14 SEAT SNACK BAR.
③ SEE ATTACHED OPERATION PERMIT FOR DETAIL ISSUED 4/20/92

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 2/4/92

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold