IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dogwood Construction DATE 19 Mar 74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N. just past Log Cabin Dennis Mobile on Right Lot # 5

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 20,100 sq ft plus

Character & Porosity of Soil Red Clay
Percolation Rate 20 m
Topography Rolling
Depth to Water Table 4'
Rock or other impervious formations 4'



Plot of System Not to Scale

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 7
Sq. Ft. 625 Linear Ft. 250'
Depth of Stone in Lines 10" plus
Water Supply: Individual ( )
Public (✓)

Installed by Eddie Yancey

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY W M Townsend DATE 19 Mar 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold