DEPARTMENT OF ENVIRONMENT...
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: 4779687196
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: FICKETT DISHNER APPLICANT: SAME
ADDRESS: 126 HOLLOW DR, STATESVILLE, NC 28625 APPLICATION DATE: 3-31-99 DATE EVALUATED: 4-12-99
PROPOSED FACILITY: 3BR S/W MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 55-54 ACRES
LOCATION OF SITE: I-77 S TO EXIT 54, 0.4 MILE ON LEFT PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☑ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	L 12%	0-48	SBK / CL	FR / SEXP					PS 0.35
2	N 15%	0-98	SBK / SCL	FR / SEXP					PS 0.35
3	L 15%	0-98	SBK / CL	FR / SEXP					PS 0.35
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	II	II
Site LTAR	0.35	0.35

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: J. HENDRICK
OTHER(S) PRESENT: F.C. DISHNER