IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR J. K. Stine DATE 12-13-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N T.R. on Log Cabin Rd. (#2136) T.L. on Rimrock Farm Rd (#2139) T.R. on Cochran Rd. (2140) ~½ mi. on Rt. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil clay loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	—	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-4%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	unk.	
			Rock or other impervious formations	none obs.	

Lot Area acreage



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"+

Water Supply: Individual ( )
Public ( )

Installed by Sammy Reavis

IMPROVEMENTS PERMIT BY David R. Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE 12-13-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold