## IREDELL COUNTY HEALTH DEPARTMENT

### (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry Carter DATE 8-13-76 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION 70 E. to Elmwood Tl across Rikard on Rd # 2308 Go Approx 1 Mile house on Rt. S. R. No. 2308

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2

| | | | | | |
|---|---|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) | Character & Porosity of Soil | Grey Clay |
| Auto. Dishwasher | Yes ( ) | No (✓) | Percolation Rate | slow |
| Auto. Wash. Machine | Yes (✓) | No ( ) | Topography | level |
| Site Suitable | Yes (✓) | No ( ) | Depth to Water Table | rock |
| Lot Area Approx 1 acre | | | Rock or other impervious formations | None |




Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Henry Sizemore

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Foster DATE 8/13/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold