IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert Thompson DATE 2-21-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 70 E to Elmwood TL on Rd 2308 - cross creek TR on Rd 2309 - cross creek Mobile Home on Left S. R. No. 2309


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	fair
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Gently to Steep + Level
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	none
			Rock or other impervious formations	none

Lot Area 4 Acres



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 216 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Daniel Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Todd Jr. DATE 2/21/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold