DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: IREDELL

SOIL/SITE EVALUATION *for* ON-SITE WASTEWATER SYSTEM

4784 45 1360 (PT

OWNER: STEPHEN MARK LITTLE APPLICANT: SAME
ADDRESS: 396 LONGVIEW RD, STVL, 28625 APPLICATION DATE: 11-17-00 DATE EVALUATED: /
PROPOSED FACILITY: 3BR MOD. PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 0.71
LOCATION OF SITE: 396 LONGVIEW RD, STVL PROPERTY RECORDED: _____
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other ~~NEXT DOOR~~
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 0%	0-36	SBK C	FI S/P SEXP					PS 0.2
		36-48	SBK / C	FR S/P SEXP					
2	L 0%	0-36	SBK / C	FI S/P SEXP					PS 0.2
		36-48	SBK C	FR S/P SEXP					
3	L 1%	0-36	SBK C	FI S/P SEXP					PS 0.15
		36-48	SBK C	FR S/P SEXP					
4	L 1%	0-36	SBK / C	FI S/P SEXP					PS 0.15
		36-48	SBK / C	FR S/P SEXP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	III
Site LTAR	0.2	0.1

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HEDRICK, LORNE COOK
OTHER(S) PRESENT: MARK LITTLE