DEPARTMENT OF HEALTH AND HUMAN SERVICES
DIVISION OF PUBLIC HEALTH, ENVIRONMENTAL HEALTH SECTION
ON-SITE WATER PROTECTION BRANCH

Sheet 1 of 2
PROPERTY ID #: 9789464190
COUNTY: Iredell

SOIL/SITE EVALUATION
***for* ON-SITE WASTEWATER SYSTEM**
(Complete all fields in full)

OWNER: Daniel Clark — APPLICATION DATE 11-23-15
ADDRESS: 349 Longview Rd — DATE EVALUATED: 12/10/15
PROPOSED FACILITY: SFD — PROPOSED DESIGN FLOW (.1949): 360 — PROPERTY SIZE: 2.99 ac
LOCATION OF SITE: 40W to Barry Dale to Longview — PROPERTY RECORDED: Yes
WATER SUPPLY: ☒ Private ☒ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☒ Auger Boring ☒ Pit ☐ Cut — TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 10%	0-15	Gr SCL	fr SE	PS	PS	W/A	W/A	PTS Drip
		15-40	Mass C	Vfi E					
		40-48+	Mass BC	fi SE					
2	L 3%	0-10	Gr SCL	fr SE	many yellow browns 31"-48"	PS	W/A	W/A	PS .25
		10-31	SBK C	fi SE					
		31-48	WABK BC	fi/fr SE					
3	L 5%	0-10	Gr SCL	fr SE	many yellow browns 24"-48" Chromas @ 24"	PS	W/A	W/A	PTS Drip
		10-20	ABK C	fi SE					
		20-24	WABK C	fi SE/E					
		24-48	WABK BC	fi/fr SE					
P 4	L 5%	0-13	Gr SCL	fr SE	Chromy 25@36"	PS	W/A	W/A	PS .25
		13-31	ABK C	fi SE					
		31-48	Platy C	fi SE					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		PS
System Type(s)		III
Site LTAR		.25

OTHER FACTORS (.1946): PS
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: H Snow
OTHER(S) PRESENT:

COMMENTS:

SOIL/SITE EVALUATION

(Continuation Sheet-Complete all field in full)

DEPARTMENT OF HEALTH AND HUMAN SERVICES
DIVISION OF PUBLIC HEALTH
ENVIRONMENTAL HEALTH SECTION
ON-SITE WATER PROTECTION BRANCH

PROPERTY ID #: 4784469196
DATE OF EVALUATION: 12/18/15
COUNTY: Iredell

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
P5	L 10%	0-9	Gr SCL	fr SE	Chroma 2 is 29", 46"	PS	W/A	W/A	PS .2
		9-29	ABlC C	fi SE					
		29-34	Platy C	fi SE					
		34-48	ABlC BC	fi/fr SE					
P6	L 10%	0-9	Gr SCL	fr SE	PS	PS	W/A	W/A	PS .2
		9-28	ABlC C	fi SE					
		28-36	ABlC C	fi SE					
		36-48	Platy C	fi SE/E					
P7	L 1%	0-10	Gr SCL	fr SE	PS	PS	W/A	W/A	PS .2
		10-33	5 ABlC C	fi SE					
		33-48	5 ABlC BC	fi SE					
P8	L 5%	0-12	Gr SCL	fr SE	Many yellow browns 36" 48" Water coming in hole @ 36"	PS	W/A	W/A	PS .25
		12-36	ABlC C	fi SE					
		36-48	Platy C	fi SE					
P9	L 3%	0-15	Gr SCL	fr SE	Many yellow browns 36-48"	PS	W/A	W/A	PS .25
		15-34	ABlC C	fi SE					
		34-46	Platy C	f SE					

COMMENTS:

LEGEND

use the following standard abbreviations

LANDSCAPE POSITION	GROUP	SOIL TEXTURE	CONVENTIONAL 1955 LTAR*	LPP 1957 LTAR*	MINERALOGY/ CONSISTENCE	STRUCTURE
CC (Concave Slope) CV (Convex Slope) D (Drainage Way) DS (Debris Slump) FP (Flood Plain) FS (Foot Slope) H (Head Slope) L (Linear Slope) N (Nose Slope) R (Ridge) S (Shoulder Slope) T (Terrace)	I	S (Sand) LS (Loamy Sand)	1.2 - 0.8	0.6 - 0.4	SEXP (Slightly Expansive) EXP (Expansive)	G (Single Grain) M (Massive) CR (Crumb) GR (Granular) SBK (Subangular Blocky) ABK (Angular Blocky) PL (Platy) PR (Prismatic)
	II	SL (Sandy Loam) L (Loam)	0.8 - 0.6	0.4 - 0.3		
	III	Si (Silt) SiCL (Silty Clay Loam) CL (Clay Loam) SCL (Sandy Clay Loam) SiL (Silt Loam)	0.6 - 0.3	0.3 - 0.15		
					MOIST	**WET**
	IV	SC (Sandy Clay) SiC (Silty Clay) C (Clay)	0.4 - 0.1	0.2 - 0.05	VFR (Very Friable) FR (Friable) FI (Firm) VFI (Very Firm v. Very Sticky)	NS (Non-sticky) SS (Slightly Sticky) S (Sticky) VS (Very Sticky)
		O (Organic)	None	None	EFI (Extremely Firm)	NP (Non-plastic) SP (Slightly Plastic) P (Plastic) VP (Very Plastic)

*Adjust LTAR due to depth, consistence, structure, soil wetness, landscape, position, wastewater flow and quality.

NOTES

HORIZON DEPTH	In inches below natural soil surface
DEPTH OF FILL	In inches from land surface
RESTRICTIVE HORIZON	Thickness and depth from land surface
SAPROLITE	S(suitable) or U(unsuitable)
SOIL WETNESS	Inches from land surface to free water or inches from land surface to soil colors with chroma 2 or less - record Munsell color chip designation
CLASSIFICATION	S (Suitable), PS (Provisionally Suitable), or U (Unsuitable)

Evaluation of saprolite shall be by pits.

Long-term Acceptance Rate (LTAR): gal/day/ft^2

Show profile locations and other site features (dimensions, reference or benchmark, and North).

