[illegible] & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Steve Harkey OWNER__ AGENT__ PHONE _____
ADDRESS _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____
PROPERTY SIZE: 30 acres

LOCATION OF SITE: _____
WATER SUPPLY: On-Site Well___ Comm. Well___ Public___ Other___ EVAL. METHOD: Auger Boring__ Pit__ Cut__

PROFILE #	1980 LANDSCP POS., SLOPE %	HORIZON DEPTH (IN.)	1945 SOIL TEXTURE	1945 SOIL STRUCTURE	1945 SOIL CONSISTENCE	
1	4% Slope	0 to 8"	L	GR		1945 WETNESS CONDITION: N/A
		8 to 36	C	ABK	1:1	1945 USK SUBSOILITE: N/A
		36 to 48	C	weak ABK	1:1	1945 RESTRICTIVE HORIZON: N/A
						1945 PROFILE CLASSIFICATION: PS
						PROFILE STAR: 13
2	4% Slope	0 to 6"	L	GR		1945 WETNESS CONDITION: N/A
		6 to 42	C	ABK	1:1	1945 USK SUBSOILITE: N/A
		42 to 48	C	weak ABK	1:1	1945 RESTRICTIVE HORIZON: N/A
						1945 PROFILE CLASSIFICATION: PS
						PROFILE STAR: 13
3	4% Slope	0 to 7"	L	GR		1945 WETNESS CONDITION: N/A
		7 to 40	C	ABK	1:1	1945 USK SUBSOILITE: N/A
		40 to 48	C	ABK	1:1	1945 RESTRICTIVE HORIZON: N/A
						1945 PROFILE CLASSIFICATION: PS
						PROFILE STAR: 13
4						1945 WETNESS CONDITION:
						1945 USK SUBSOILITE:
						1945 RESTRICTIVE HORIZON:
						1945 PROFILE CLASSIFICATION:
						PROFILE STAR:
5						1945 WETNESS CONDITION:
						1945 USK SUBSOILITE:
						1945 RESTRICTIVE HORIZON:
						1945 PROFILE CLASSIFICATION:
						PROFILE STAR:

ACCEPTABLE SPACE (1945) Yes SITE CLASSIFICATION (1945) PS SITE LONG-TERM ACCEPTANCE RATE 13
OTHER FACTORS (1945) _____ SYSTEM TYPE Conv. Gravity
EVALUATED BY: L. C. Moore AUTHORIZED REPRESENTATIVE _____
COMMENTS: _____

DRAFT

000559