02428

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Reid Swicegood DATE 12-11-84 PERMIT NO.

PHONE: Business Home

LOCATION 64 E TR on Barry Oak Rd before Co. line on left.


SUBDIVISION NAME Swicegood MHP LOT NO. 1 SECTION OR BLOCK NO. S. R. No.

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 29,000 SF

Character & Porosity of Soil Clayey
Percolation Rate 14 gal/sq ft/day
Topography 2+ 6%
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Kenneth Chaffin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS:

CERTIFICATE OF COMPLETION BY

EXISTING SYSTEM CHECKED BY: L. C. Moore DATE 12-11-84

DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold