IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 215474

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4786039882

APPLICANT: Ramon Speller APPLICANT ADDRESS: 253 St Jill Circle

SITE ADDRESS: 214 Fifth Creek Rd. PHONE: 704-402-8564 ALT. PHONE: N/A

SITE DIRECTIONS: Hwy 64 E TL Fifth Creek Rd Property on Right on Corner of Fifth Creek & Coarris Dr.

SUBDIVISION: Blueberry Hill Estates SECTION: 2 LOT # 27 LOT AREA: 2.14 acres DESIGN FLOW: 360gpd L.T.A.R.: 0.25

Septic Tank 1000 (gal) STB 525 Date 5-22-16
Pump Tank N/A (gal) PT N/A Date N/A
Pump Make N/A Model Infiltrator Serial # IT8-6
Nitrification Fields 1 # Lines 4 Linear Ft: 360
Trench Width 36" Max. Trench Bottom Depth 24" Gravel Depth N/A

☑ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI
System Description: 25% Reduction
Repair System Description: 25% Reduction
Maintenance Agreement Required: ☐ YES ☑ NO
☐ GRAVITY ☐ PRESSURE

☐ Residence No. Bedrooms 3
☐ Business No. Persons 6
☐ Other No. Employees
☐ Slab ☑ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☑ Public ☐ Community

Comments / Conditions:

INITIAL SITE SKETCH

See attached design by Michael Athanas & Associates

AS BUILT SKETCH

Installed as drawn

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☑ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☑ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Valerie Stevens Date: 1-4-16 Installed by: Rowan Septic

IMPROVEMENT PERMIT by: Justin Henderson Date: 12-29-15 OPERATION PERMIT by: [signature] Date: 07/21/16

AUTHORIZATION TO CONSTRUCT by: Justin Henderson Date: 1/4/16 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK

S 18°00' 36" E
1/2" EIR 311.40'
N 75° 16' 32" E 280.80'
S 75° 39' 33" W
80.00'
N 13° 29' 17" W
321.66'
PB
POB
1/2"
E 1/2 SEC
C.L. R/W (Paved)
Garris Dr.
Scale 1"=50'
N
27
60' House
100'
Replacement Area
Additional Area
Sta Creek Rd