DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

PROPERTY I.D.#: _____ SHEET ____ OF ____
DATE: _____
COUNTY: _____

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT mark Phillips
ADDRESS _____
OWNER ___ AGENT: ___ PHONE: _____
APPLICATION DATE: _____ DATE EVALUATED _____
PROPOSED FACILITY: _____
PROPERTY SIZE: 2 acres +
LOCATION OF SITE: Lot 28 Blueberry Hills
WATER SUPPLY: On-site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring / Pit / Cut

PROFILE #	.1940 LANDSCP POS / SLOPE(%)	HORIZON DEPTH (IN)	.1941 SOIL TEXTURE	.1941 SOIL STRUCTURE	.1941 SOIL MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1 Ridge to Linear 1090		0 to 10	L	GR ✓				.1942 Wetness Cond. N/A
		10 to 24	C	SBK	1:1			.1943 Depth/.1956 Sapr. 36"
		24 to 36	Transition					.1944 Restrictive Hori. 36" Rock
		36"	Saprolite + Rock					.1948 Profile Class. PS
								Profile LTAR .13
2 Ridge to Linear 1090		0 to 10	L	GR				.1942 Wetness Cond. N/A
		10 to 24	C	SBK	1:1			.1943 Depth/.1956 Sapr. 36"
		24 to 36	Transition					.1944 Restrictive Hori. Rock
		36"	Saprolite Rock					.1948 Profile Class. PS
								Profile LTAR .13
3 Ridge		0 to 12	L	GR				.1942 Wetness Cond. N/A
		12 to 30	C	SBK	1:1			.1943 Depth/.1956 Sapr. 36"
		30 to 36	Transition					.1944 Restrictive Hori. Rock
		36"	Saprolite + weathered Rock					.1948 Profile Class. PS
								Profile LTAR .13
4								.1942 Wetness Cond.
								.1943 Depth/.1956 Sapr.
								.1944 Restrictive Hori.
								.1948 Profile Class.
								Profile LTAR

AVAILABLE SPACE (.1945) yes OTHER FACTORS (.1946) _____ SITE CLASSIFICATION (.1948) PS
SYSTEM TYPE Conv. Gravity LONG-TERM ACCEPTANCE RATE(S) .13
EVALUATED BY: J. Lineaw OTHER(S) PRESENT: Pat murphy mark Phillips
COMMENTS: _____