Ike Slaughter Lindsey

.10282

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

(Ike Slaughter) OWNER OR CONTRACTOR J.S. Evans DATE 8-1-89 PERMIT NO. 116-1-A-13

PHONE: Business _____ Home _____

LOCATION 64 E TL Fifth Creek Rd TR into Blueberry Hill TL back across Lake S. R. No. _____

SUBDIVISION NAME Blueberry Hills LOT NO. 13 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes (✓)	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Character & Porosity of Soil Clayey
Percolation Rate 14
Topography 2 to 6%
Depth to Water Table 10'+
Rock or other impervious formations none


Lot Area 6.76 acres

___ Basement with Plumbing ___ Basement without Plumbing ✓ No Basement

Size of Tank 1500 S.T. 1000 gal pump T. Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 12"

Water Supply: Individual ( ) Public (✓)



Plot of System

Installed by Julian Bowles

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: X Thomas R Jr

Place Excess riser over Pump & bring to ground surface - use 2" check valve & 2" disconnect.

IMPROVEMENTS PERMIT BY P.C. moore

COMMENTS: use Pump that will deliver 50 gal/min at 20' Total Heat. Wire Pump & Alarm according to Iredell Co Building Insp. Specs. Set Float to Pump 250 gal / Pumping.

CERTIFICATE OF COMPLETION BY P.C. moore DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold