DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Daniel Chambers OWNER: ~~AGENT~~: PHONE: 878-9198
ADDRESS: 126 Signal Hill Dr Apt 108 Statesville, 28677 APPLICATION DATE: DATE EVALUATED: 7/7/94
PROPOSED FACILITY: DW mobile Home
PROPERTY SIZE: ~149 x 149
LOCATION OF SITE: Ledgehill Rd on RF 0.1 from Cool Springs Rd
WATER SUPPLY: On-Site Well ✓ (Proposed) Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ~~Pit~~ ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	
1	Linear ~6%	0-8	LOAM	GR		.1942 WETNESS CONDITION - N/A
		8-30	Clay	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		30-48	B2Clay	ABK	1:1	.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - Prov. Suitable
						PROFILE LTAR - 0.3 gpd/ft²
2	Linear ~2-3%	0-6	LOAM	GR		.1942 WETNESS CONDITION - N/A
		6-30	Clay	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		30-48	Clay	Weak SBK	1-1	.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - Prov Suitable
						PROFILE LTAR - 0.35 gpd/ft²
3	Linear ~8%	0-9	Loam	Gr		.1942 WETNESS CONDITION - N/A
		9-48	Clay	ABK	1:1	.1943/.1956 SAPROLITE - N/A
						.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - 0.3 gpd/ft²
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) _____ SITE CLASSIFICATION (.1948): _____ SITE LONG-TERM ACCEPTANCE RATE: _____
OTHER FACTORS(.1946) _____ SYSTEM TYPE _____
EVALUATED BY: J.C. Moore OTHER(S) PRESENT: Kelly R. Sheeks, Daniel Chambers
COMMENTS: _____

DRAFT