ON-SITE WASTEWATER SECTION

COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Gerald Stilphen APPLICANT: _____

ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____

PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: _____

LOCATION OF SITE: Bridge Bottom Rd PROPERTY RECORDED: _____

WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____

EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut

TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	3%	0-4	sl gr	fr ss sp		48"			PS 0.3
		4-18	c sbk	fr vss vp					
		18-48	cl sbk	fr ss sp					
2		0-7	sl gr	fr ss sp		48			PS 0.3
		7-20	c sbk	fr vss vp					
		20-48	cl sbk	fr ss sp					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	3	
System Type(s)	Trench (Conv)	Grav Conv
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): _____

SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____

OTHER(S) PRESENT: _____