DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: F.J. Pishner APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY _____ PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: _____
LOCATION OF SITE lot 1 PROPERTY RECORDED: _____
WATER SUPPLY ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER ☒ Sewage ☐ Industrial Process ☐ Mixed Regular chamber S-80

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	Linear	0-28	SBk C	SS SP		48			P/S 0.3
		28-48	SBk C/CL mi	SS SP					
2	Linear	0-8	SBk L	SS SP		48			P/S 0.3
		8-30	SBk C	SS SP SS SP					
		30-48	SBk CL	SS SP					
3	Linear	0-24	SBC			48			P/S 0.3
		24-38	SC						
		38-48	CL						
4	Repair Linear	0-4	L			48			P/S 0.3
		4-48	C						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

00264