HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: John Irby OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE: Lot 18 Campbell Est.
WATER SUPPLY: On-Site Well Comm. Well Public Other EVAL. METHOD: Auger Boring Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	Linear 12%	0 to 4	L	GR		.1942 WETNESS CONDITION	N/A
		4 to 36	C	SBK	1:1	.1943/.1956 SAPROLITE	N/A
		36 to 48	CL	weak SBK	1:1	.1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
2	Linear 10%	0 to 6	L	GR		.1942 WETNESS CONDITION	N/A
		6 to 36	C	SBK	1:1	.1943/.1956 SAPROLITE	N/A
		36 to 48	CL	weak SBK	1:1	.1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
3	Linear 12%	0 to 6	L	GR		.1942 WETNESS CONDITION	N/A
		6 to 30	C	SBK	1:1	.1943/.1956 SAPROLITE	N/A
		30 to 48	CL	weak SBK	1:1	.1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) Y/N SITE CLASSIFICATION (.1948): SITE LONG-TERM ACCEPTANCE RATE: .35
OTHER FACTORS(.1946) SYSTEM TYPE
EVALUATED BY: P. C. Moon OTHER(S) PRESENT: John Irby
COMMENTS:

DRAFT

000787