DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Lynn Barker OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 4-14-94
PROPOSED FACILITY: Single Family
PROPERTY SIZE: 4+ acres
LOCATION OF SITE: Lot 3 Campbell Est.
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	
1	Linear 2%	0 to 8	L	GR		.1942 WETNESS CONDITION - N/A
		8 to 30"	C	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		30 to 118"	C	weak SBK	1:1	.1944 RESTRICTIVE HORIZON - N/A
						.1945 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
2	Linear 2%	0 to 8"	L	GR		.1942 WETNESS CONDITION - N/A
		8 to 27	C	SBK	1:1	.1943/.1956 SAPROLITE - ~~30~~ 38"
		27 to 38	Transition			.1944 RESTRICTIVE HORIZON - N/A
		38 to 48	Saprolite			.1945 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
3						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1945 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1945 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1945 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) ___ SITE CLASSIFICATION (.1945): PS SITE LONG-TERM ACCEPTANCE RATE: .35
OTHER FACTORS(.1946) ___ SYSTEM TYPE Conv. Gravity
EVALUATED BY: J. C. Moore OTHER(S) PRESENT: Lynn Barker
COMMENTS:

DRAFT