HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: _____
PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Zantle Kinder OWNER: AGENT: PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 11-9-94
_____ PROPOSED FACILITY: _____
_____ PROPERTY SIZE: 1/2 acre +
LOCATION OF SITE: _____
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other _____ EVAL. METHOD: Auger Boring ___ Pit ✓ Cut ✓

PROFILE #	1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	
1	linear 2% to 4%	0 to 12"	CL	GR	I:I	.1942 WETNESS CONDITION - N/A
		12 to 48	sandy loam	saprolite		.1943/.1956 SAPROLITE - 12"
						.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .4 recharacterized Sunday
2	linear 2% to 4%	0 to 12"	CL	GR		1942 WETNESS CONDITION -
		12 to 48	sandy loam	saprolite		.1943/.1956 SAPROLITE - Same
						.1944 RESTRICTIVE HORIZON - as
						1948 PROFILE CLASSIFICATION - above
						PROFILE LTAR -
3	linear 2% to 4%	0 to 12"	CL	GR		.1942 WETNESS CONDITION -
		12 to 48"	sandy loam	saprolite		.1943/.1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON - Same as
						.1948 PROFILE CLASSIFICATION - above
						PROFILE LTAR -
4						1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON -
						1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948) PS SITE LONG-TERM ACCEPTANCE RATE: .4
OTHER FACTORS(.1946) _____ SYSTEM TYPE conv. Gravity
EVALUATED BY: D. C Moore OTHER(S) PRESENT: Zantle Kinder
COMMENTS: _____

DRAFT

001124