DELL COUNTY HEALTH DEPARTMENT

(CV)

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 14922 PIN# 4788156490

OWNER OR APPLICANT Brian Atwell PHONE: Business 704-975-2879 Home

ADDRESS 4410 Amity Hill Rd Cleveland NC 27013 DATE 4-1-08

LOCATION Old Mocksville Rd, past Vaish mill RD on Right

SUBDIVISION BLOCK / SECTION LOT LOT AREA 3308 sf SITE CLASS B5 DESIGN FLOW 480 L.T.A.R. .2

Septic Tank: 1000 Gallons: STB 760 Date 11-30-07

Pump Tank: Gallons: PT Date

Pump Make: Model Date

Nitrification Field: No Fields Square Feet 2400 Serial No. Linear Feet 600

No Lines 6 Trench Width 36" Max Trench Bottom Depth 36"

☑ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI

System Description: 25% Reduction

Repair System Description: 25% Reduction

Maintenance Agreement Required: ☐ Yes ☑ No

Gravel Depth Gravity ☐ Pressure ☐ Slab ☐ Crawl Space ☑ Basement w/plumbing ☐ Basement wo/plumbing

☑ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons No. Employees

Water Supply: ☑ Individual ☐ Public ☐ Community

Comments/Conditions: After future house built - mobile home is to be disconnected from Septic System

Comments/Conditions: Rake - Lime Suitable for installation

INITIAL SITE SKETCH

1" = 200'

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed:

Improvement Permit by: Kelly Cook date 4/2/8

Authorization to Construct by: Kelly Cook date 4-1-08

Installed by: Tim Abee

Operation Permit by: Jan Hogg, R.S. date 14 April 08

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK