Jerry Campbell

202756

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jerry Campbell DATE 2-12-14 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64 E - L. ON Rd 2158 (Old Mocksville Rd) Cross Yadkin River - Rt on Rd #2145 - Go 1 1/4 Miles - New House on Rt. S. R. No. 2145

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Red Clay	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	unk	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to Rt Side	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	unk	
			Rock or other impervious formations	none	

Lot Area 1 Acre

1 well



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by J.W. Jones

Location of the proposed Accessory Building addition does not appear to impact the existing on-site septic system or well.**NOTE: 30x40

David A. Lee REHS Date: 04/15/14
ICHD-Environmental Health Division

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steven Todd DATE 2/12/14

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold