43796

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

14808

OWNER OR CONTRACTOR ROBERT FROMMIE DATE 7/2/92 PERMIT NO. 12D-A-78

PHONE: Business 872-6533 Home

LOCATION OLD MOCKSVILLE ROAD NE, TR SOCIETY CHURCH ROAD, TR SUNFLOWER ROAD, ON (R) ~ 1.5 MILES S.R. No.


SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.

MODULAR
House [✓] Mobile Home [ ] Business [ ] Other

No. Bedrooms 4 No. Bathrooms 3
Garbage Disposal Unit Yes [ ] No [✓]
Auto. Dishwasher Yes [✓] No [ ]
Auto. Wash. Machine Yes [✓] No [ ]
Lot Area ACREAGE

Soil Characteristics PS
Application Rate 0.40 GPD / FT²
Topography 4-6% LINEAR SLOPE
Depth to Water Table >4'
Rock or other impervious formations NONE

[✓] Basement with Plumbing [ ] Basement without Plumbing [ ] No Basement [ ] Crawl Space



Plot of System (Not to Scale)

TP 12/6/91
Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 12"
Water Supply: Individual [✓] WELL
Public [ ]

Installed by JAMES HUNTER

I understand and agree to install a septic tank system as specified on this Improvement Permit.

LONG DRIVEWAY

Signed:

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

SUNFLOWER ROAD

IMPROVEMENT PERMIT BY STEVE HEDRICK

COMMENTS

① KEEP WELL SITE MINIMUM 100 FEET FROM SYSTEM
② REPAIR AREA IS 100% CONVENTIONAL GRAVITY-FED

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 7/2/92

EXISTING SYSTEM CHECKED BY DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold