(38)

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

13636

OWNER OR CONTRACTOR JOHNNY ABEE DATE 12/19/91 PERMIT NO. 12J-A-49

PHONE: Business _____ Home _____

LOCATION US 21 N, TR MT. BETHEL CH. ROAD, TL RIMROCK ROAD, ON (L) JUST BEFORE SHAW ROAD S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 247.5 AC

Character & Porosity of Soil PS

Percolation Rate .35 GPD / FT²


Topography 6-8% RS

Depth to Water Table >4'

Rock or other impervious formations NONE / SCATTERED SURFACE ROCK

ACP 10/15/91

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 690 Linear Ft. 230

Depth of Stone in Lines 12"

Water Supply: Individual (✓) WELL

Public ( )

Installed by SAMMY REAVIS

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HEARICK

COMMENTS: _____

CERTIFICATE OF COMPLETION BY STEVE HEARICK DATE 12/19/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold