DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of _
PROPERTY ID #:
COUNTY: [redacted]

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: PAUL SEABOLT APPLICANT: SAME
ADDRESS: 110 GRANITE RIDGE, COOLEEMEE APPLICATION DATE: 12-14-99 DATE EVALUATED: 1-7-00
PROPOSED FACILITY: 3BR DW MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 2.808 ACRES
LOCATION OF SITE: RIMROCK EST. 25/26 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	N 17%	0-17	SBK / C	FR / NEXP		4			[redacted] 4
		17+	ROCK	—					
2	N 16%	0-54	SBK / C SAPMIX	FR / NEXP			PS		PS 0.33
3	N 18%	0-44	SBK / C SAPMIX	FR / NEXP			PS		PS 0.33
4	N 17%	0-20	SBK / C	FR / NEXP		4			4
		20+	ROCK						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	II
Site LTAR	0.33	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HODRICK
OTHER(S) PRESENT: STEVE JARRETT