HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED: 12J-A-90
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: ERIC D. ANDERSON OWNER: ✓ AGENT: PHONE: (910) 468-2905
ADDRESS: 178 CRANFILL ROAD APPLICATION DATE: 6/2/95 DATE EVALUATED: 6/12/95
HARMONY, NC 28634 PROPOSED FACILITY: 3BR D/W MH
PROPERTY SIZE: 1.54 AC
LOCATION OF SITE: US 21 N, TR NC 901, TR CRANFILL ROAD ON (L) AT PAVEMENT END
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ✓ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	L 2%	0-32	C	SBK	1:1/ FI	1942 WETNES CONDITION 5
		32-48	SiC	WSBK	1:1/ FR	.1943/.1956 SAPROLITE 5
						.1944 RESTRICTIVE HORIZON 5
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35 GPD/FT²
2						1942 WETNES CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
3						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
4						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
5						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR

AILABLE SPACE (.1945) 3 SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT²
THER FACTORS(.1946) NONE SYSTEM TYPE CONVENTIONAL GRAVITY
VALUATED BY: S. HEDRICK OTHER(S) PRESENT PREACHER GAITHER + SON
OMMENTS:

DRAFT