WASTEWATER SECTION

COUNTY: IREDELL

4789 12 2996

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

: ROBERT TEMPLETON APPLICANT: SAME

SS: 590 MOCKSVILLE HWY, STATESVILLE, 28625 APPLICATION DATE: _____ DATE EVALUATED: 7-13-98

SED FACILITY: 3BR MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 0.7 ACRE

TION OF SITE: RIMROCK ESTATES LOT #6 PROPERTY RECORDED: _____

SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____

ATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut

F WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

.1940 LAND-SCAPE POSITION/ SLOPE %	SOIL MORPHOLOGY (.1941) HORI-ZON DEPTH (IN.)	.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
L 6%	0-6	GR SCL	FR /	—	—	PS	—	PS 0.3
	6-42	SBK C	FI /					
	42-48	SAPROLITE MVX						
L 6%	0-5	GR SCL	FR /	—	—	PS	—	PS 0.3
	5-42	SBK C	FI /					
	42-48	SAPROLITE						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
ailable Space (.1945)	PS	PS
stem Type(s)	CONV. GRAV.	CONV. GRAV.

OTHER FACTORS (.1946): NONE

SITE CLASSIFICATION (.1948): PS

EVALUATED BY: S. HEDRICK

OTHER(S) PRESENT: