HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 12K
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: K. PERRY CARTNER OWNER: ✓ AGENT: PHONE: 546-2141
ADDRESS: RT 1, BOX [redacted] 319 APPLICATION DATE: 3/8/99 DATE EVALUATED: 3/8/99
HARMONY, NC. 28634 PROPOSED FACILITY: 2 BR MH - FUTURE 3BR HOUSE
PROPERTY SIZE: 4 AC.
LOCATION OF SITE: OLD MOCKSVILLE RD, TR NC 901 E, TR HAYES ROAD
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ✓ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	L 6%	0-12	SC	SBK	1:1 / FR	.1942 WETNES CONDITION S
		12-48	C	ABK	1:1 / FI	.1943/.1956 SAPROLITE S
						.1944 RESTRICTIVE HORIZON S
		MIXED		MAYODAN S.S.		.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.3 GPD
2	L 6%	0-10	SC	SBK	1:1 / FR	.1942 WETNES CONDITION S
		10-48	C	ABK	1:1 / FI	.1943/.1956 SAPROLITE S
						.1944 RESTRICTIVE HORIZON S
		MIXED		MAYODAN S.S.		.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.3 GPD
3						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
4						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
5						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.30 GPD
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: MIKE CARTNER
COMMENTS:

DRAFT