IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Edward Edmonston DATE 24 Nov 16 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hy 21 N to Bethel Church Rd #2136 on Right Go to #2137 on Left Go 1/2 mile Trailer on Left S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area acreage

Character & Porosity of Soil Gravelly Cl
Percolation Rate none
Topography 6-10% Slope
Depth to Water Table nl
Rock or other impervious formations nl



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Leonard Adams

IMPROVEMENTS PERMIT BY _____

COMMENTS: Wells checked on ord.

CERTIFICATE OF COMPLETION BY W A Howard DATE 24 Nov 16

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold