IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR W Lee Ketchie DATE 3/ 04/ 75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64 E. to under I 40 and Turn left on Old 21 N. T. L. on Old 21 N. T. L. on 1st driveway. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Red Clay Loam
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	none
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to rear and left of home
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4'
			Rock or other impervious formations	none

Lot Area average



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 225 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Hall Septic Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY [illegible] DATE 3/ 04/ 75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold