SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Stanley Reynolds OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE: Saddlebrook lot 18
WATER SUPPLY: On-Site Well Comm. Well Public Other EVAL. METHOD: Auger Boring Pit Cut

PROFILE #	.1940 LANDSCP POS (A)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1949/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	linear 8 to 10%	0 to 6	L GR		PS	PS	PS	PS	.3
		6 to 36	C SBK	SEAP SS SP					
		36 to 48	Heavy cl. W SBK	SEAP SS SP					
2	linear 10%	0 to 8	L GR		PS	PS	NA	PS	.3
		8 to 38	C SBK	SEAP SS SP					
		38 to 48	Heavy cl. W SBK	SEAP SS SP					
3									
4									
5									

AVAILABLE SPACE (.1945) YES SITE CLASSIFICATION (.1948): SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: E. C. Moore OTHER(S) PRESENT: Mr + Mrs Stanley Reynolds
COMMENTS:

0023775