01533

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Southern V. A. Brazil DATE 8-20-84 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION 64E - T Low 64E at Davie County Line / T Low SR 2148 to L on 2145 (Bristol Valley Rd) 6a to 2nd Dwlg on Left

SUBDIVISION NAME Saddlebrook LOT NO. 8 SECTION OR BLOCK NO. _____ S. R. No. 2145

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3	No. Bathrooms 2		
Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil Clay Loam Sandy Loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate 60 Min/Inch
Auto. Wash. Machine	Yes (✓)	No ( )	Topography Level to Rolling
Site Suitable	Yes (✓)	No ( )	Depth to Water Table 10'
Lot Area 1.331 Acres			Rock or other impervious formations Shallow Rock

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 700 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by A K Grading Co.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 8/20/84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold