IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jimmy Gaither DATE 2-5-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I-40 E - to Davie County Line - exit on 64 E. TL on Rd #2148 House at end of Rd. at intersection of Rd 2145 S. R. No. 2145

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 10 acres


Character & Porosity of Soil CF B2

Percolation Rate 2 mins

Topography 2 - 6% slope

Depth to Water Table 4 ft

Rock or other impervious formations None Noted in a few Large Rock in upper Line



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Wilkes Septic Tank Service

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Todd DATE 2/5/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold