DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of _
PROPERTY ID #:
COUNTY: IREDELL

4788869829

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: WILLIAM GIBSON APPLICANT: SAME
ADDRESS: 1380 OSWALT AMITY CLEVELAND APPLICATION DATE: 6-12-01 DATE EVALUATED: 7-12-01
PROPOSED FACILITY: 3BR W/ALT PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 6.0 ACRES
LOCATION OF SITE: SOCIETY CH. ROAD PROPERTY RECORDED:
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	L 3%	0-20"	SBK C	FI SS/SP SPP					PS 0.3
		20-48"	SBK CL	FR SPP					
2	L 4%	0-22"	SBK C	FI SS/SP SPP					PS 0.3
		22-48"	SBK CL	FR SPP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	III
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HEDRICK
OTHER(S) PRESENT: WILLIAM GIBSON