DEPARTMENT OF ENVIRONMENT, HEALTH AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: 4779 or 4181
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: BRADLEY FOX APPLICANT: SAME
ADDRESS: 609 GREENHILL ROAD, MOCKSVILLE APPLICATION DATE: _____ DATE EVALUATED: 11-5-98
PROPOSED FACILITY: 3BR HOUSE PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 5.05 ACRES
LOCATION OF SITE: JAMES C. GAITHER LOT #7 PROPERTY RECORDED: _____
WATER SUPPLY: ☑ Private OR ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	L 1%	0-48	SBK / C	FI/S/P/NEXP	Chrm 3 @ 38"				0.25 PS
2	L 1%	0-48	SBK / C	FI/S/P/NEXP	Chrm 3 @ 40"				0.25 PS
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	II
Site LTAR	0.25	0.25

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S HEDRICK
OTHER(S) PRESENT: BRAD FOX