DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET____ OF____

PROPERTY I.D.#:____

DATE:____

COUNTY:____

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT:____ OWNER___AGENT:___PHONE:____

ADDRESS: Harry Davis APPLICATION DATE:____ DATE EVALUATED____

PROPOSED FACILITY:____

LOCATION OF SITE:____ PROPERTY SIZE: 5 acres

WATER SUPPLY: On-site Well____ Comm. Well___ Public___ Other____ EVAL. METHOD: Auger Boring___ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1		0 to 2	L	GR				.1942 Wetness Cond. - N/A
		2 to 18	C	SBK	SEAP			.1943 Depth/.1956 Sapr. - N/A
	ridge	18 to 36	CL	SBK	NEAP			.1944 Restrictive Hori. - N/A
	10/0	36+ to 46	B/C	No	NEAP			.1948 Profile Class. - PS
								Profile LTAR - .25
2		0 to 4	L	GR				.1942 Wetness Cond. - N/A
		4 to 24	C	SBK	NEAP			.1943 Depth/.1956 Sapr. - N/A
	ridge	24 to 36	CL	SBK	NEAP			.1944 Restrictive Hori. - N/A
	8 to 10	36 to 46	B/C	No	NEAP			.1948 Profile Class. - PS
								Profile LTAR - .35
3		0 to 10	L	GR				.1942 Wetness Cond. - N/A
		10 to 24	C	SBK	NEAR			.1943 Depth/.1956 Sapr. - NA
	ridge	24 to 36	CL	SBK	NEAP			.1944 Restrictive Hori. - N/A
	8 to 10	36 to 46	B/C	No	NEAP			.1948 Profile Class. - PS
								Profile LTAR - .3
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945)____ OTHER FACTORS (.1946)____ SITECLASSIFICATION (.1948) PS

SYSTEM TYPE____ LONG-TERM ACCEPTANCE RATE(S) .3

EVALUATED BY: L. C. Moore OTHER(S) PRESENT: Harry Davis

COMMENTS:____