DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM 4798-17-7841

OWNER: FLEETWOOD HOMES OF STATESVILLE APPLICANT: RENEE POTEAT
ADDRESS: 1270 NORTHSIDE DR STVL, 28625 APPLICATION DATE: 9-23-02 DATE EVALUATED: 10-17-02
PROPOSED FACILITY: 3BR D/W PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.3 ACRES
LOCATION OF SITE: US 21 N, TR NC 901, TR HAYES FARM, 0.5 MI (R) PROPERTY RECORDED: ___
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 8%	0-6	GR SCL	VFR SE/P	CHROMA C MOTTLING @ 28"				PS 0.25
		6-28	ABK C	FR SS/P SE/P					
		28-48	ABK C	FI S/P SE/P					
2	L 8%	0-4	GR SCL	VFR SE/P	CHROMA C MOTTLING @ 30"				PS 0.25
		4-30	ABK C	FI SS/P SE/P					
		30-48	ABK C	FI S/P SE/P					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	II
Site LTAR	0.25	0.25

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HENDRICK
OTHER(S) PRESENT: RENEE POTEAT