IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Harper DATE 12 Jan 77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Off Statesville Rd. to V-Point. T.R. to 2nd house on right before Liberty Baptist Church Parsonage. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil Clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	none
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6% Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	6'
			Rock or other impervious formations	6'

Lot Area acreage



Plot of System

Size of Tank Repair Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 475 Linear Ft. 190
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Lemmy Lewis

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY W. M. Howard DATE 12 Jan 77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold