IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

10532
OWNER OR CONTRACTOR Roger Dale Sharpe DATE 2/8/89 PERMIT NO. IRE-A-54

PHONE: Business _____ Home _____

LOCATION 2 1/2 W 901.5 NH on R across from Pleasant View S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Adq Suitable
Percolation Rate 2 3/4
Topography Adq
Depth to Water Table 10'+
Rock or other impervious formations None


Lot Area 18.6 AC

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 120 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)



Plot of System

Installed by D/I Backhoe

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY D Weaver

COMMENTS: _____

CERTIFICATE OF COMPLETION BY D Weaver DATE 10-31-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold