DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of _
PROPERTY ID #: _____
COUNTY: IREDELL

479901 6238.(P)

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: JODY GARNER APPLICANT: MIKE TEMPLETON A-1 MH
ADDRESS: 1258 E. MEMORIAL HWY HARMONY APPLICATION DATE: 4-1-99 DATE EVALUATED: 4-13-99
PROPOSED FACILITY: 3BR D/W MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.0 ACRE
LOCATION OF SITE: CORNER OLD MOCKSVILLE RD & NC 901 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 2%	0-6	GR / SL	VFR / SEXP					PS 0.25
		6-19	SBK / C	FR / SEXP					
		19-25	SBK / C	FI / SEXP					
		25-35	SBK / SiC	FR / SEXP					
		35-48	WSBK / CL SAP	FR / SEXP					
2	SLIGHT H 2%/3%	0-7	GR / SL	VFR / SEXP					PS 0.25
		7-20	SBK / C	FR / SEXP					
		20-36	SBK / SiC	FI / SEXP					
		36-48	WSBK / CL SAP	FR / SEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	II
Site LTAR	0.25	0.25

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: STEVE HENDRICK
OTHER(S) PRESENT: MIKE TEMPLETON