IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

Alb. Fisk Prop

OWNER OR CONTRACTOR Ernest Campbell DATE 8 Aug 73 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 4 Rd to Harmony - Rt on 901 to Clarksbury Church - Rt. on Rd # 2122 - 4th to 1st left, 1st house on left S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 3 acres


Character & Porosity of Soil Red Clay

Percolation Rate Low

Topography Level

Depth to Water Table none

Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 562 Linear Ft. 225

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Robert Fisk

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY William M. Howard DATE 8 Aug 73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold