...OF ENVIRONMENTAL HE... PROPERTY ...
...WASTEWATER SECTION COUNTY REDELL
12K-1-A-16

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT Jeffrey Dalton OWNER AGENT PHONE 946-7905
ADDRESS 160 Guilford Road APPLICATION DATE 12/30/94 PROPOSED FACILITY 3BR House REV. DATE 1/3/94
Harmony, NC 28634 PROPERTY SIZE 5 ACRES
LOCATION OF SITE US 21 N, TR NC 901, TL GUILFORD, ~ 0.25 MILE on (R)
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD Auger Boring PR ___ Cut ___
Lot #16 E.B. Vick Property

Profile	1940 Landscape Pos. Slope %	Horizon Depth (in.)	1941 Soil Texture	1941 Soil Structure	1941 Soil Consistence	
	L 4%	0-48	C	SBK/ABK	FI/FI	1941 Wetness Condition S 1941 Drainage Class S1 1941 Restrictive Horizon S 1941 Profile Classification PS Profile Limit 0.3
	L 6%	0-48	C	SBK/ABK	FI/FI	1941 Wetness Condition S 1941 Drainage Class S 1941 Restrictive Horizon S 1941 Profile Classification PS Profile Limit 0.3
						1941 Wetness Condition 1941 Drainage Class 1941 Restrictive Horizon 1941 Profile Classification Profile Limit
						1941 Wetness Condition 1941 Drainage Class 1941 Restrictive Horizon 1941 Profile Classification Profile Limit
						1941 Wetness Condition 1941 Drainage Class 1941 Restrictive Horizon 1941 Profile Classification Profile Limit

1941 Site Classification PS 1941 Site Long-Term Acceptance Rate 0.3
1941 Space S
1941 Restrictions NONE System Type CONV. GRAV.
Evaluated by S. HEDRICK Others Present WILLA TURNER, JEFFREY DALTON

DRAFT