DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of _
PROPERTY ID #:
COUNTY: RANDOLPH

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM 4779-49-5317

OWNER: REV. JEFFREY CRUTCHFIELD APPLICANT: PIEDMONT HOUSING
ADDRESS: 270 PINEY GROVE RD, HARMONY APPLICATION DATE: 11-9-99 DATE EVALUATED: 11-19-99
PROPOSED FACILITY: 3BR D/W M PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.00 ACRE
LOCATION OF SITE: 270 PINEY GROVE ROAD PROPERTY RECORDED: ___
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 4%	0-48	SBK / C	FR / NEXP					PS 0.3
2	L 5%	0-48	SBK / C	FR / NEXP					PS 0.3
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	III
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HEDRICK
OTHER(S) PRESENT: JEFF CRUTCHFIELD & PARENTS CHAD (PIEDMONT HOUSING)