IREDELL COUNTY HEALTH DEPARTMENT

12687 (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION 39719
13282 (Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR KENNETH HANELINE DATE 9/6/91 PERMIT NO. 12K-A-35A

PHONE: Business _____ Home _____

LOCATION US 21 N, TR NC 901 E, LAST DRIVE ON (L) BEFORE DAVIE COUNTY LINE S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business (✓) Other WORKSHOP W/ ONE EMPLOYEE @ 100 GPD

No. Bedrooms — No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	DS
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	.4 GPD / FT²
Auto. Wash. Machine	Yes ( )	No (✓)	Topography	8-10% HS
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	>4'
Lot Area RESTRICTED			Rock or other impervious formations	NONE

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement CRS 3/25/90



Plot of System

Size of Tank 800 Gals.

Nitrification Field:
No. of Lines 1
Sq. Ft. 255 Linear Ft. 85
Depth of Stone in Lines 12"

Water Supply: Individual (✓) WELL
Public ( )

Installed by BILLY GRIMES

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

DAVIE CO.

NC 901 E

IMPROVEMENTS PERMIT BY STEVE HEDRICK

COMMENTS: _____

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 9/6/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold