DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: TRANSYLVANIA

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

4800 7.5036F.

OWNER: G. F. MASON JR APPLICANT: SAME
ADDRESS: 121 ALMA DRIVE, STVL APPLICATION DATE: 2-15-99 DATE EVALUATED: 3-3-99
PROPOSED FACILITY: 3BR(H)/Apt PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 5.00 ACRES
LOCATION OF SITE: 121 ALMA DRIVE PROPERTY RECORDED: ___
WATER SUPPLY: ☑ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 10%	0-48	SBK / C	FR-FI-SS/SERP					PS 0.3
2	N 8%	0-42	SBK / GRAVELLY C	FR-FI-SS/SERP					PS 0.3
		42+	ROCK						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (1945)	S	S
System Type(s)	II	II
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HEDRICK
OTHER(S) PRESENT: GEORGE MASON