IREDELL COUNTY HEALTH DEPARTMENT 40350

13004 (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR JACK CLEMENTS DATE 7/12/91 PERMIT NO. 14KL-A-21

PHONE: Business _____ Home _____

LOCATION NC 115N, TL DAMASCUS CH. RD, 2ND LOT ON (L) BEFORE HARNESS FARM RD. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area AMPLE

Character & Porosity of Soil PS
Percolation Rate .4 GPD / FT2
Topography 10-15% LS
Depth to Water Table >4'
Rock or other impervious formations NONE

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

ACP 5/29/91



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓) WELL
Public ( )

Installed by A-1 BACKHOE

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HEDRICK

COMMENTS: _____

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 7/16/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold