IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Reams DATE 28 Dec 76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 115 N passed Central Savings to Rd 1583 on left. Go passed Rock Hill Baptist Ch. to dirt Rd on right # 1591. House on left appx. 2 mile. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 3 Acres


Character & Porosity of Soil Clay Loam

Percolation Rate Good

Topography 2-6% Slope

Depth to Water Table 4'

Rock or other impervious formations 4'



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 700 Linear Ft. 20
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Wayne Mayes

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY [signature] DATE 28 Dec 76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold