DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: 4801 90 6897 (PT)
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: RICHARD CAMPBELL APPLICANT: BILLY FAINE / OWNER
ADDRESS: 270 SHOEMAKER FARM, STVL APPLICATION DATE: 8-28-00 DATE EVALUATED: 9-22-00
PROPOSED FACILITY: 3BR D/W MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.00 ACRE
LOCATION OF SITE: BESIDE 270 SHOEMAKER FARM RD, STVL, 28625 PROPERTY RECORDED: _____
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	H 8%	0-14	GRAVELLY SBK-GR / SCL	VFR / SEXP					PS 0.4
		14-38	SBK / SC	FR SH / SEXP					
		38-48	SAPROLITE	FR / SEXP					
2	H 10%	0-16	GRAVELLY SBK-GR / SCL	VFR / SEXP					PS 0.4
		16-40	SBK / SC	FR SH / SEXP					
		40-48	SANDY LOAM SAPROLITE	FR / SEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	III
Site LTAR	0.4	0.4

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: STEVE HENDRICK
OTHER(S) PRESENT: RICHARD CAMPBELL, BILLY FAINE