06871

I

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR RICHARD DALE HARRIS DATE 7-9-87. PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 115 Nabors Gatrail School - T.L. on Mtn. View Rd. - go to Buckhead Rd - T.L. - ½ mi. on R. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. PT. 53 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Grav. Suitable.
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	5 gal./sq. ft.
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-10%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10+
Lot Area	Ample		Rock or other impervious formations	None impervious

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Sherman Dees

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 7-9-87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold