IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 153377 PIN # 4803-73-4720 DATE 25 November 08

OWNER or APPLICANT David & Ann Marie Rolando PHONE: Business 603-986-5781 Home:

OWNER or APPLICANT ADDRESS PO Box 2428 PMB 11965 Pensacola, Fl.

LOCATION / DIRECTIONS Hwy 115N TL Livengs mill rd. TR Barkers Grove on Rt.

SUBDIVISION BLOCK / SECTION LOT # LOT AREA 8.41Ac. DESIGN FLOW 480 gpd L.T.A.R. 0.3 gpd/ft²

Septic Tank 1000 Gallons: STB 1012 Date 9-4-8

Pump Tank Gallons: P T Date

Pump Make Model Serial #

Nitrification Field No Fields 1 No Lines 4 Linear Feet 100'

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A

☑ New System ☐ Repair ☐ Expansion System Type I II (III) IV V VI

System Description: 25% Reduction

Repair System Description: 25% Reduction

Maintenance Agreement Required ☐ YES ☑ NO

☑ GRAVITY ☐ PRESSURE

☑ Residence No. Bedrooms 4

☐ Business No. Persons

☐ Other No. Employees

☐ Slab ☐ Crawl Space

☑ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☑ Private ☐ Public ☐ Community

Comments / Conditions: Follow contour

Comments / Conditions

INITIAL SITE SKETCH

Please see Attached Site sketch.

AS BUILT SKETCH

The proposed 8'x18' POOL addition does not appear to impact the existing septic system.

**NOTE: Stay 15'+ From building part of septic

R.S.

Date: 8-27-09

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ IMPROVEMENT PERMIT w / plat valid without expiration ☑ IMPROVEMENT PERMIT w / site plan valid for 60 mos. ☑ AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.

Owner / Applicant Signature: David P. Rolando Date 25 Nov. 08

Improvement Permit by: R.S. Date 25 Nov. 08

Authorization to Construct by: R.S. Date 25 Nov. 08

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: C&G

Operation Permit by: James Date: 4-7-9

Existing System Inspected by: Date:

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant